



# Water Heater Replacement

Town of Jupiter Building Department

Project Address: \_\_\_\_\_ Property Owner: \_\_\_\_\_

The following information must be provided by the installer and attached to the permit at the time of inspection. Verifying the following should provide an opportunity for the installer to successfully pass the required inspection provided all work has been done in a professional manner. It is our goal to close out water heater replacement permits during the initial inspection. Failure to accomplish that task typically results in a reinspection fee. Your cooperation toward achieving this goal would be appreciated.

**\*NOTE Change from Tank to Tankless Water Heater requires Plan Review\***

**Tankless water heater install in Condos provide Utility Provider & HOA Approval Letter if upgrading electric panel**

Water Heater Type: Tank (Gals.) \_\_\_\_\_ or Tankless: \_\_\_\_\_

Electric: \_\_\_\_\_ or Gas: \_\_\_\_\_

Hard Wired: \_\_\_\_\_ or Cord & Plug: \_\_\_\_\_ (\*) see note

Old Heater Size: \_\_\_\_\_ Watts

New Heater Size: \_\_\_\_\_ Watts

Existing Circuit Breaker Size: \_\_\_\_\_

Circuit Breaker Required: \_\_\_\_\_

Existing Wire Size: \_\_\_\_\_

Are Cord & Plug in good condition? \_\_\_\_\_ (\*) 20 Amp cord and plugs must be removed and hard wired, no exceptions!

Is relief valve piped full size & not trapped? \_\_\_\_\_

Does relief pipe have visible air break next to appliance? \_\_\_\_\_

Is flue connected properly? \_\_\_\_\_

Are full set of instructions on site? \_\_\_\_\_

All selected heater elements must be clearly identified and properly labeled for the inspection. All components must be compatible and listed by a qualified evaluation agency.

Signature:	
Date:	